



DESIGN NOTES:

- 1 - CONCRETE 5,000 PSI AT 28 DAYS.
- 2 - TRENCH BASE AND COVER RATED FOR H-20 LOADING.
- 3 - ALL PIECES SHALL BE NUMBERED ON ONE SIDE.
- 4 - MARK STRAIGHT TRENCH UNITS: 1-15 & 17-26.
- 5 - MARK TEE SECTION UNIT: 16.
- 6 - KNOCK-OUTS TO BE LOCATED ON INTERIOR OF TRENCH WITH SPRAY PAINT.

8' STRAIGHT TRENCH COVER
25 REQUIRED

6' STRAIGHT TRENCH COVER
1 REQUIRED, UNIT: 18

2' STRAIGHT TRENCH COVER
1 REQUIRED, UNIT: 18



PRECAST OF MAINE
139 MAIN STREET, P.O. BOX 307
TOPSHAM, ME 04086
207-729-1628, FAX: 207-729-8710

PROJECT: CABLE TRENCH

BIGELOW SUBSTATION
CARRABASSETT VALLEY, ME

CUSTOMER:
BANCROFT CONTRACTING

ENGINEER:
CMP

DATE: 5/11/09

DRAWN BY: MJB

DRAWING NUMBER:

SCALE: NTS

001 REV. 3